


All new and existing services require the U5871-XL-200 for the Main Meter.
The existing socket must be replaced.

U5871-XL-200 (Single Phase w/ 200 Amp Main and 8 Circuits) or
U5059-X-2/200-K3L (Single Phase 320 w/ 2 - 200 Amp Mains)

U6513-XL-BL-ALT (200 Amp Heat+ Socket)

ex. 1 - Electric Heat



ex. 2 - Heat Pump



Mechanical Ventilation
ERV/HRV Allowed W/Electric Heating



Members Main Panel

Members Secondary Panel
for Qualified Heat+ Units

*Electric/Heat Pump Water Heater
Must be in Main Panel

All wiring must meet current NES Code and Electrical Inspections